

**Pisgah Forest Elementary School – HVAC Piping Improvements
Transylvania County Schools
Brevard, North Carolina**

ADDENDUM NUMBER 2

McGill Associates Project No. 22.00607

This **ADDENDUM NUMBER 2** is being issued this March 10, 2023 to parties who hold Contract Documents for the subject project with Transylvania County Schools. This Addendum Number 2 shall become a part of the Contract Documents and its receipt shall be acknowledged on the bid documents at the time of bidding.

The following additions, revisions and/or clarifications shall be made to the Contract Documents:

GENERAL

1. The following is a response to a question from a bidder “can the ceiling tiles and grid be left out during the project?”

Temporary provisions within the work area would not require ceiling tiles and grid to be put back until the end of the project but all other ceiling mounted devices including but not limited to lights, fire alarm, speakers and air distribution shall be functional and safe. This does not apply in the kitchen and cafeteria, where ceilings will need to be present whenever the school is in session.

ADDENDUM NUMBER 2 issued this the 10th day of March 2023.

END OF ADDENDUM NO. 2

MARCH 10, 2023
PISGAH FOREST ELEMENTARY SCHOOL – HVAC PIPING IMPROVEMENTS
TRANSYLVANIA COUNTY SCHOOLS
BREVARD, NORTH CAROLINA